

Residential facilities that use septic systems in Southern Nevada

If you increase the number of beds in your facility, you may need to revise your septic system to account for an increase in residents using the septic system.

If you install a commercial kitchen in your existing facility, the septic system may also need revising.

Any revisions to the septic system need to be approved by the Southern Nevada Health District (SNHD) Plan Review Section.

When the municipal sewer is within 400 feet of the nearest property line and a septic system is failing or needs replacement with a larger septic system, a new permit cannot be issued by SNHD and the customer must connect to municipal sewer. Most conversions from Residential to Commercial septic systems will result in needing a connection to Municipal sewer.